



Ron Chapman, MD, MPH
Director & State Health Officer

State of California—Health and Human Services Agency
California Department of Public Health

DRINKING WATER FIELD OPERATIONS BRANCH

50 D STREET, SUITE 200, SANTA ROSA, CA 95404

PHONE: (707) 576-2145 / FAX: (707) 576-2722

INTERNET ADDRESS: www.cdph.ca.gov



EDMUND G. BROWN JR.
Governor

April 25, 2014

Water System No. 4901269

Grant Zoldowski
United Rentals
791 East 64th Street
Denver, CO 80229

CITATION NO. 02-18-14C-011

**TOTAL COLIFORM MAXIMUM CONTAMINANT LEVEL (MCL) VIOLATION FOR
FEBRUARY 2014**

Enclosed is a Citation issued to the United Rentals (System) public water system.

Your System will be billed at the Department's hourly rate (currently estimated at \$126.00) for the time spent on issuing this Citation since this is an enforcement action for noncompliance with State regulations. At this time, we have spent approximately one hour on enforcement activities associated with this violation. You will receive a bill sent from our Fee Billing Unit in Sacramento on approximately August 1, 2014. This bill will contain fees for any enforcement time spent on your System.

If you have any questions regarding this matter, please contact Cindi Lee of my staff at (707) 576-2422 or me at (707) 576-2006.

Sincerely,

Janice M. Thomas, P.E.
Sonoma District Engineer
Drinking Water Program

Enclosures

STATE OF CALIFORNIA
DEPARTMENT OF PUBLIC HEALTH

Name of Public Water System: United Rentals

Water System No: 4901269

To: Grant Zoldowski
United Rentals
791 East 64th Street
Denver, CA 80229

Issued: April 25, 2014

CITATION FOR NONCOMPLIANCE

With Total Coliform Maximum Contaminant Level for February 2014

Section 116650 of the California Health and Safety Code (CHSC), authorizes the issuance of a citation for failure to comply with a requirement of California Safe Drinking Water Act (CHSC, Division 104, Part 12, Chapter 4, commencing with Section 116270), or any regulation, standard, permit or order issued thereunder.

The Division of Drinking Water and Environmental Management of the State of California Department of Public Health (Department) hereby issues a citation to the United Rentals (System) for failure to comply with Title 22, California Code of Regulations (CCR) Section 64426.1.



APPLICABLE AUTHORITIES

Section 116650 of the CHSC states in relevant part:

- (a) If the department determines that a public water system is in violation of this chapter or any regulation, permit, standard, citation, or order issued or adopted thereunder, the department may issue a citation to the public water system. The citation shall be served upon the public water system personally or by certified mail. Service shall be deemed effective as of the date of personal service or the date of receipt of the certified mail. If a person to whom a citation is directed refuses to accept delivery of the certified mail, the date of service shall be deemed to be the date of mailing.
- (b) Each citation shall be in writing and shall describe the nature of the violation or violations, including a reference to the statutory provision, standard, order, citation, permit, or regulation alleged to have been violated.
- (c) A citation may specify a date for elimination or correction of the condition constituting the violation.
- (d) A citation may include the assessment of a penalty as specified in subdivision (e).
- (e) The department may assess a penalty in an amount not to exceed one thousand dollars (\$1,000) per day for each day that a violation occurred, and for each day that a violation continues to occur. A separate penalty may be assessed for each violation.



1 California Code of Regulations (CCR), Section 64426.1 states in relevant
2 part:

3
4 (b) A public water system is in violation of the total coliform MCL {maximum
5 contaminant level} when any of the following occurs:

6 (1) For a public water system which collects at least 40 samples per
7 month, more than 5.0 percent of the samples collected during any
8 month are total coliform-positive; or

9 (2) For a public water system which collects fewer than 40 samples per
10 month, more than one sample collected during any month is total
11 coliform-positive; or

12 (3) Any repeat sample is fecal coliform-positive or E. coli-positive; or

13 (4) Any repeat sample following a fecal coliform-positive or E. coli-positive
14 routine sample is total coliform-positive.

15
16 **STATEMENT OF FACTS**

17
18 The Department has received laboratory results for thirteen bacteriological
19 samples collected during February 2014 from the System. All samples were
20 analyzed for the presence of coliform bacteria. Nine of the thirteen samples
21 tested positive for coliform bacteria.
22

23
24 **DETERMINATIONS**

25
26 **THE DEPARTMENT HAS DETERMINED:**
27



1 The System violated Title 22 of the CCR, Section 64426.1, in that the
2 System failed to comply with the maximum contaminant level (MCL) for total
3 coliform bacteria during the month of February 2014.
4

5 **DIRECTIVES**
6

7
8 United Rentals is hereby directed to take the following actions:
9

10 1. Comply with Section 64426.1, Title 22, of the California Code of
11 Regulations in all future monitoring periods.
12

13 2. Notify all persons served by the System of the MCL violation in
14 conformance with Section 64463.4 and 64465, Title 22 of the CCR,
15 and as follows:
16

17
18 a) Completion of Attachment A to include the name, address, and
19 telephone number of a System representative as a source of
20 additional information concerning the public notice. **You must**
21 **also give a legible, written description (preferably typed) of**
22 **the corrective actions taken by the water system to prevent**
23 **this violation from occurring in the future. You must use the**
24 **space provided in Attachment A for this written description.**
25

26
27 b) Post the notice contained in Attachment A, **after it has been**
completed in accordance with (a) above, in conspicuous

1 locations throughout the area served by the System. Posting
2 must begin no later than **May 19, 2014** and must continue for
3 seven days.

4
5 c) Provide public notice for this violation in accordance with Section
6 64465(c), Title 22 or the CCR, which requires for each non-
7 English speaking group that exceeds 1,000 residents or 10% of
8 the residents in a community (whichever is less) that the public
9 notice contain information in the appropriate language(s)
10 regarding the importance of the notice, or contain a telephone
11 number or address where such residents may contact the water
12 system to receive a translated copy of the notice or to receive
13 assistance in the appropriate language.
14
15

16
17 3. The System shall complete the attached Compliance Certification
18 form and return it to the Department within 10 days of the public
19 notice being given to the system customers but in no case later than
20 **June 6, 2014. A copy of the notice posted in conspicuous**
21 **locations must be attached to the form.**
22

23
24 The Department reserves the right to make such modifications to this
25 Citation, as it may deem necessary to protect public health and safety.
26 Such modifications may be issued as amendments to this Citation and shall
27 be effective upon issuance.



1 Nothing in this Citation relieves the System of its obligation to meet the
2 requirements of the California Safe Drinking Water Act (CHSC, Division 104,
3 Part 12, Chapter 4, commencing with Section 116270), or any regulation,
4 standard, permit or order issued thereunder.

5
6 All submittals required by this Citation shall be submitted to the Department

7
8 at the following address: Janice M. Thomas, P.E.
9 Department of Public Health
10 Drinking Water Program
11 50 D Street, Suite 200
12 Santa Rosa, CA 95404

13
14
15
16
17
18 **PARTIES BOUND**

19
20 This Citation shall apply to and be binding upon the System, its officers,
21 directors, agents, employees, contractors, successors, and assignees.
22

23
24
25
26
27 **SEVERABILITY**

28 The directives of this Citation are severable, and the System shall comply
29 with each provision thereof notwithstanding the effectiveness of any
30 provision.
31



FURTHER ENFORCEMENT ACTION


Division 104, Part 12, Chapter 4, (commencing with Section 116270) of the California Health and Safety Code authorizes the Department to: issue additional citations with assessment of penalties if the System continues to fail to correct a violation identified in a citation; take action to suspend or revoke a permit that has been issued to a public water system if the System has violated applicable law or regulations or has failed to comply with orders of the Department; and petition the superior court to take various enforcement measures against a public water system that has failed to comply with orders of the Department. The Department does not waive any further enforcement action by issuance of this citation.

Janice M. Thomas

Janice M. Thomas, P.E.
Sonoma District Engineer
Drinking Water Program

April 25, 2014

Date



Attachments

Certified Mail No. 7010 1870 0000 5927 0106

4901269/Compliance
140425-02-18-14C-011-4901269-21/cel



1
2 **COMPLIANCE CERTIFICATION**

3
4 **Citation Number 02-18-14C-011**

5 **Name of Water System: United Rentals**

6 **System Number: 4901269**

7 **Certification**

8 I certify that the users of the water supplied by this water system were notified of the
9 bacteriological violations of Title 22, California Code of Regulations (CCR) for the
10 compliance period of February 2014.

11 Required Action

Date Completed

12 Complete Attachment A, as required in Directive 2(a)

13 Public Notification – Continuous Posting for 7 Days

14
15 _____
16 Signature of Water System Representative

Date

17 **Attach a copy of the notice posted.**

18
19 **THIS FORM MUST BE COMPLETED AND RETURNED TO THE DEPARTMENT**
20 **NO LATER THAN JUNE 6, 2014**

21 **Disclosure:** Be advised that Section 116725 and 116730 of the California Health and Safety Code
22 states that any person who knowingly makes any false statement on any report or document
23 submitted for the purpose of compliance with the attached order may be liable for a civil penalty not
24 to exceed five thousand dollars (\$5,000) for each separate violation for each day that violation
25 continues. In addition, the violators may be prosecuted in criminal court and upon conviction, be
26 punished by a fine of not more than \$25,000 for each day of violation, or be imprisoned in county jail
27 not to exceed one year, or by both the fine and imprisonment.



IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

United Rentals Had Levels of Coliform Bacteria Above the Drinking Water Standard During February 2014

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did to correct the situation. Please share this information with other people who drink this water, especially those who may not have received this notice directly. You can do this by posting this notice in a public place or giving out copies by hand or mail.

What happened? We routinely monitor our drinking water for contaminants. We took thirteen water samples to test for the presence of coliform bacteria during February 2014. Nine of our samples showed the presence of coliform bacteria. The standard is that no more than one sample per month may test positive for bacteria. The positive samples were tested further for fecal coliform. **No fecal coliform or E. coli were found.** However, our drinking water exceeded the maximum contaminant level allowed for total coliform bacteria, as specified in Section 64426.1, Title 22 of the California Code of Regulations (CCR).

What does this mean? The California Department of Public Health (Department) sets drinking water standards and has determined that the presence of total coliform bacteria is a possible health concern. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. Coliforms were found in more drinking water samples than allowed. This was a warning of potential problems and a violation of the regulations.

What should I do? This is not an emergency. If it had been, you would have been notified immediately. People with severely compromised immune systems, infants, and some elderly may be at increased risk. These people should seek advice about drinking water from their health care providers. General guidelines on ways to lessen the risk of infection by microbes are available from EPA's Safe Drinking Water Hotline at (800) 426-4791. If you have other health concerns related to the consumption of this water, you may wish to consult your doctor.

Has the problem been resolved? What corrective actions have been taken to prevent this violation from occurring in the future?

This notification of the public is being done in compliance with Section 64463.4, Title 22 of the CCR as a means of keeping the public informed.

Persons wishing more information should contact:

(name)

(address)

(phone number)